


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



IAPMO R&T Product Listing



This IAPMO R&T Listing is current as of 11/18/2019

Product: Test Gates (ABS & PVC) File No. 4898

Issued To: Mainline (BWV) Manufacturing Inc.
12530 128TH STREET
EDMONTON, AB T5L 1C8
CANADA

Identification: Manufacturer's name or trademark, nominal size or model number, the designation (e.g., ABS or PVC), the CSA Standard designation (CSA B181.1 or CSA B181.2), and any other markings required by law. Test caps and test gates shall include the pressure tested to. Markings shall be permanent or indelible. When printed markings are used, letters and numerals shall be of a color that contrasts with the color of the fittings. The product shall also bear the cUPC® certification mark.

Characteristics: Test caps and test gates with ABS or PVC Housing. To be installed in accordance with the manufacture's instructions and the requirements of the latest edition of the Uniform Plumbing Code and the National Plumbing Code of Canada.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)
National Plumbing Code of Canada

Products are in compliance with the following standard(s):

IAPMO IGC 122-2005ae1 and CSA B1800-2018

MODELS:

Test-Eze™ (Gate)	
Test-Eze™ Tee (Gate)	
<u>Model No.</u>	<u>Size</u>
ML-3TTG	3" (To be used w/ 3" ABS or PVC ML-3TT housings)
ML-3TZ	3" (To be used w/ 3" ABS and PVC "Adapt-a-Valve" housings)
ML-4TZ	4" (To be used w/ 4" and PVC "Adapt-a-Valve" housings)

This IAPMO R&T Listing is current as of 11/18/2019